

1 SENATE BILL NO. 431
2 INTRODUCED BY LIND

3
4 A BILL FOR AN ACT ENTITLED: "AN ACT REVISING THE REQUIREMENTS FOR FLOW-THROUGH HOT
5 SPRINGS POOLS; AND AMENDING SECTION 50-53-115, MCA."

6
7 BE IT ENACTED BY THE LEGISLATURE OF THE STATE OF MONTANA:

8
9 Section 1. Section 50-53-115, MCA, is amended to read:

10 "50-53-115. Special requirements for flow-through hot springs pools. In addition to the other
11 requirements of this chapter and rules promulgated under this chapter, flow-through hot springs pools must meet
12 the following requirements:

- 13 (1) The temperature of the pool water must be 106 degrees F or less.
- 14 (2) The water must have sufficient clarity at all times so that a black disc, 6 inches in diameter, is readily
15 visible when placed on a white field at the deepest point of the pool.
- 16 (3) The pool water must be maintained at a pH of no less than 7.2 and not greater than ~~8.5~~ 9.4.
- 17 (4) The pool must provide sufficient water volume exchange to produce an 8-hour turnover of the entire
18 volume of pool water to waste. In addition:
19 (a) the pool, and all surfaces that flow into the pool, must be drained, cleaned, and sanitized every 72
20 hours; or
21 (b) the pool must be disinfected, and a chlorine residual of 1 to 3 parts per million or a bromine residual
22 of 3 to 6 parts per million must be maintained in the pool at all times.
- 23 (5) Signs must be prominently posted that specify pool rules and special health hazards associated with
24 swimming or bathing in flow-through hot springs pools. The contents of the signs must be determined by
25 department rule. The department, in developing rules under this section, shall consult with flow-through hot
26 springs pool owners."

27 - END -